

**Laboratory Gwalior**

**Test Report**

Type of sample: Water Sample  
 Particular of sample : collected / not collected by PHED  
 Particular of sender:- Principal Delhi Public Academy B-5 D.D. Nagar, Gwalior (M.P.)

Sample No.	Place of Collection and Details of Sample	Date of collection
1	Drinking Water	10.06.2024
2	-	-
3	-	-
4	-	-

Particular of Sample :  
 Date of Receipt: 10.06.2024  
 Time of Receipt: 11:40 AM  
 Lab Reference No:  
 Date of Analysis: 12.06.2024

**Nature of Study – Chemical and Bacteriological Analysis**

S.N.	Characteristics	Unit	As Per BIS-10500-2012 For Drinking Water			
			Permissible limit	Acceptable Value	In the absence of alternate source	RESULT
<b>PHYSICAL TESTE</b>						
1	Turbidity	NTU	1.0	5.0	2.0	Sample 1 Sample 2 Sample 3 Sample 4
2	Color	Cobalt	5	15	-	-
3	Taste & Odour		Unobjectionable	Objectionable	Unobjectionable	-
4	Temperature	C°	-	-	-	-
<b>CHEMICAL TESTE</b>						
5	PH Value	PH Scale	6.5 To 8.5	No Relaxation	6.9	-
6	Alkalinity	Mg/L	200	600	210	-
7	Chlorides (as Cl)	Mg/L	250	1000	30	-
8	Nitrate as No3	Mg/L	45	45	7	-
9	Total hardness	Mg/L	200	600	180	-
10	Calcium as Ca	Mg/L	75	200	38	-
11	Magnesium as mg	Mg/L	30	100	20	-
12	Iron	Mg/L	0.3	1.0	0.11	-
13	Free Chlorine	Mg/L	0.2	1.0	-	-
14	T.D.S.	Mg/L	500	2000	192	-
15	Fluoride	Mg/L	1.0	1.5	0.12	-
16	Sulphate sa SO4	Mg/L	200	400	06	-
<b>BECT. FEACAL TESTE</b>						
17	MPN of coliform	per 100 ml	Nil	Nil	-	-
18	Faecal Coliform	Per 100 ml	Nil	Nil	-	-

- This report should not be provided partially or fully without approval of signatory authorities for legal purposes.
- It is Recommended that acceptable limit is to be implemented values in excess those mentioned under "Acceptable" under the water not suitable, but still may be tolerated in the absence of an alternate source, but up to the limits indicated under the "permissible limit in the absence of alternate Source".
- The results refer only to tested samples and parameters tested.
- samples will be stored for a period of 10 days from the date of issue of report.
- This Lab does not hold any responsibility for variation in results for samples kept on hold for want of clarification.

Lab Incharge  
 P.H.E. Division Gwalior (M.P.)  
 P.H.E. Division Gwalior (M.P.)

Signature of Analyst  
 District Water Testing Lab  
 P.H.E. Division Gwalior

No. 258  
 PHED/Date :- 14/06/2024

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

APPENDIX - XIII

No. 258

Dated: 14/06/2024

It is certified that an inspection team headed by Mr. Arvind Bajpai, Sub Eng. / Lab Incharge

Smt. Anita Jayant Chemist (PHED Incharge) (Name of Officers with designation) from

Delhi Public Academy B-5 D D Nagar Incharge (Name of Department/ Office) inspected the

(Name & Address of the school) on 14/06/2024 (date of inspection) and found that the

DELHI PUBLIC ACADEMY (Name of school) has safe drinking water

facilities for the students and members of staff of the institution and is maintaining the hygienic

sanitation condition in the school building & the campus as per norms prescribed by the Central/

State/ U.T. Govt.

The above is valid for a period of One year [14/06/2024 to 13/06/2025]

Lab Incharge  
Signature with Seal  
PHED Division Incharge (M.P.)  
Mr. Arvind Bajpai

Name

Designation

Sub Engineer / Lab Incharge

Name & Address of the Office / Department : PHED Incharge

To

DELHI PUBLIC ACADEMY

B-5, D.D. Nagar, Gurgaon (M.P.)

(Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.